



In-Service Above Ground Storage Tank Internal and External Condition Assessment



ERPI Buried Pipe Reference Guide

“It is probable that tanks fall under Federal, State, or Local regulatory jurisdiction and currently compliance may be managed by another department at your generation station, but responsibility for compliance and reporting will be required as part of your buried pipe program and may be included in the scope of INPO audits.”

Comprehensive Inspection

Check for condition assessment integrity and condition of coating systems:

- Exterior Coating condition
- Concrete foundations and visible footings
- Structural components (stiffeners and wind rods)
- Ladders, vents, safety devices
- Interior Coating condition
- Wall and Floor Plates
- Cathodic protection system functionality
- Overflow Pipe, weir boxes and bug screens

ROV Inspection

- No Downtime
- Full Inspection
- No Confined Space Entry
- Better Documentation
- Not for Hydro Tanks



Cleaning Methods

- Drain Tank
- Chemical Cleaning
- Robotic Method – On line
- Diver Method – On line



CORRTECH
CORROSION UNDERSTOOD

Interior Corrosion Environment

- Above Water
- Submerged
- Galvanic
- Couples



CORRTECH
CORROSION UNDERSTOOD




11 07 2022



11 07 2022




























B-scan and statistical assessment

Extreme value statistical
exterior B-scan ultrasonic
thickness measurements
1,000s of data points

Performed with tank on line


Tmin calculations both
AWWA and API





Statistical Assessment Wall Thickness

- Calculations for Tmin provided
- Approximately 1,066 thickness measurements each in analysis for shell course 1 and shell course 2
- Tmin exceeded in data set shell course 2

Percent area of Shell Course 2 below TMIN (AWWA) of 0.472-in	40.818%
Percent area of Shell Course 2 Below T min (API 653) of 0.349-in	27.455%
<hr/>	
<i>Summary Data</i>	<i>Percentile</i>
	P10
Mean	0.480367273
Standard Error	0.004186147
Median	0.561
Mode	0.598
Standard Deviation	0.138838794
Sample Variance	0.019276211
Kurtosis	-1.306940991
Skewness	-0.590370222
Range	0.453
Minimum	0.170
Maximum	0.623
Sum	528.404
Count	1100
<hr/>	
	10%
	P25
	50%
	P75
	90%
	P99
	99%
	Bin
	0.279
	0.337
	0.561
	0.598
	0.603
	0.225
	0.250
	0.619
	0.275
	0.300
	0.325
	0.375
	0.400
	0.425
	0.500
	0.525
	0.550
	0.575
	0.600
	0.625
	More
<hr/>	
	Frequency




Percent area of Shell Course 1 below TMIN (AWWA) of 0.515-in	0.909%
Percent area of Shell Course 1 Below T min (API 653) of 0.349-in	0.000%
<hr/>	
<i>Summary Data</i>	<i>Percentile</i>
	P10
Mean	0.609912727
Standard Error	0.001087594
Median	0.615
Mode	0.648
Standard Deviation	0.036071404
Sample Variance	0.001301146
Kurtosis	7.179210423
Skewness	-1.862585634
Range	0.298
Minimum	0.369
Maximum	0.667
Sum	670.904
Count	1100
<hr/>	
	10%
	P25
	50%
	P75
	90%
	P99
	99%
	Bin
	0.5669
	0.591
	0.615
	0.64
	0.647
	0.655
	0.500
	0.525
	0.550
	0.575
	0.600
	0.625
	0.650
	0.675
	More
<hr/>	
	Frequency





ICCP Systems Potential Controlled



Repair & Protection Methods

- Typical mechanisms and remediation strategy
- Repairs
- Coatings and Linings
- Impressed Current Cathodic Protection, ICCP, auto potential control
- Remote monitoring corrosion rate and rectifier operation
- Monitoring Durations
 - Mechanism intervention strategies
 - Optimal intervention timing





Questions?

Scott Paul, PE
Technical Director
CorrTech Inc.

508-435-0090 Office
774-276-0351 Cell
Spaul@CorrTech-inc.com

References

- EPRI Buried Pipe Reference Guide
- AMPP RP-0285 “Corrosion Control of underground Storage Tank Systems by Cathodic Protection”
- Inspection standards cited
 - API 653, inspection, repair and reconstruction
 - API 570, piping systems
 - API 575, low pressure tanks
 - ASME, piping and high-pressure storage
 - STI, SP001-00, Inspection shop fabricated tanks
 - UL 142, construction standards